Official copies of these procedures are maintained at this website.

Before using a printed copy, verify that it is the most current version by checking the document issue date on this website. Signed copies of these official procedures are maintained at the Training Office.

C-A OPERATIONS PROCEDURES MANUAL

## **ATTACHMENT**

## 8.31.b Bag Filter Maintenance

	8.31			
	6.51			
	Hand Pro	ocessed Changes		
PC No.	<u>Date</u>	Page Nos.	<u>Initials</u>	
	Approved: <u>Signature on File</u>			
	Collid	ler-Accelerator Departme	ent Chairman	

## **Checklist for Bag Filter Maintenance**

Job	WCS #:	
	(If the step does not apply; write NA in "Check" column)	
		Check
1.	Refer to RWP # for radiological conditions and controls.	
2.	LOTO if required	
3.	Open bypass	
4.	Floor drains within 15 ft. are plugged	
5.	Close isolation valves	
6.	Relieve pressure	
7.	Drain vessel	
8.	Change filters	
9.	Solid waste in plastic bag	
10.	Seat bag in housing	
11.	Check seal or O-ring	
12.	Fill & Vent system	
13.	Open Isolation valves	
14.	Close bypass	
15.	Leak check	
16.	Remove LOTO if required	
17.	Activation check and/or contamination check all items removed as indicated by H.P.	
18.	Transfer waste water to approved drum/tank	
Sign	nature: Date:	